



SERVICE WITH 90° TAP

SERVICE ASSEMBLY

ITEM	DESCRIPTION
A	BRONZE CORP. STOP
B	BRONZE COMPRESSION JOINT
C	POLYETHYLENE TUBING WITH TRACER WIRE (BLUE HDPE FOR POTABLE AND PURPLE HDPE FOR RECYCLED WATER)
D	BRONZE ANGLE CURB STOP, FLANGE W/WING LOCK
E	BRONZE SADDLE PER SECTION II-B1-2.08
F	FACE OF CURB TO BE MARKED " <u>W</u> " FOR POTABLE WATER AND " <u>RW</u> " FOR RECYCLED WATER.

NOTES:

1. THE SERVICE LINE SHALL REST ON UNDISTURBED EARTH IN THE BOTTOM OF THE TRENCH WITH A 36" MINIMUM COVER IN THE RUN BETWEEN THE MAIN AND THE CURB.
2. FOR METER BOX INSTALLATION SEE DWG W-19.
3. STAINLESS STEEL INSERT STIFFENERS SHALL BE USED AT CORP. AND ANGLE STOPS IN POLYETHYLENE SERVICE LINES WHEN RECOMMENDED BY THE FITTING MANUFACTURER.
4. COLOR OF POLYETHYLENE TUBING SHALL BE:
BLUE FOR POTABLE WATER SERVICE
PURPLE FOR RECYCLED WATER SERVICE
5. TRACER WIRE TIE INTO THE WATER MAIN TRACER WIRE USING A SPLIT BOLT CONNECTOR.
6. WARNING TAPE (3") SHALL FOLLOW THE SERVICE LINES.

Dublin San Ramon Services District

REVISION DATE
JUN 2025

1 1/2" - 2" SERVICE INSTALLATION

REVISED BY
RM

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-8