



NOTES:

1. SEE THE APPROVED MATERIAL LIST FOR METER BOX SCHEDULE
2. H20 TRAFFIC LOAD RATED BOXES & LIDS TO BE USED IN TRAFFIC AREAS.
3. ALL METER BOXES MUST BE SET TRUE, PERPENDICULAR TO STREET, AND FLUSH WITH SIDEWALK.
4. MINIMUM SPACE BETWEEN BOXES IN MULTIPLE METER INSTALLATIONS SHALL BE 2".
5. DO NOT SET METER BOXES ON PRIVATE PROPERTY.
6. LID TO BE ONE PIECE, MARKED WATER, AND TOUCH-READ READY WITH 2" PROBE HOLE, 5/16" DEEP RECESS, 4-1/8" DIA.
7. IN SLOPED AREA METER BOX MAY REQUIRE REDWOOD RETAINING WALLS.
8. METER BOXES AND LIDS IN TRAFFIC AREAS SHALL BE H-20 TRAFFIC RATED. INSTALL 6" CONCRETE COLLAR (6" DEEP) AROUND TRAFFIC-RATED METER BOXES.
9. METER BOXES OUTSIDE OF TRAFFIC AREAS AND NOT IN SIDEWALK SHALL HAVE 6" WIDE COLLAR (4" DEEP), SMOOTH BROOM FINISHED.
10. RECYCLED WATER METER BOX INSTALLATION SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES PER SECTION IV-B1-2.04.
11. METERS TO BE INSTALLED BY DSRSD ONLY.

Dublin San Ramon Services District	REVISION DATE JUN 2025
METER BOX INSTALLATIONS 5/8 INCH TO 2 INCH	REVISED BY RM
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-19